## Message

From: Brett Gleitsmann [bgleitsmann@rcac.org]

**Sent**: 7/7/2017 2:46:37 PM

To: Rapicavoli, Emmanuelle [Rapicavoli.Emmanuelle@epa.gov]

CC: Greenberg, Leslie [Greenberg.Leslie@epa.gov]; Pablo Figueroa [pfigueroa@rcac.org]; Angela Hengel

[ahengel@rcac.org]

Subject: Hopi update

## Hi Emmanuelle,

Here is a brief summary of this past week's work in Hopi:

- Second Mesa Day School Arsenic results came back as non-detect again and so it seems like we've got the
  system working well. I've recommended that they continue to monitor on a monthly basis to track the condition
  of the filters.
- Polacca I met with Sharon, Alfonso and Cody this week for the first time and will be back up in the coming
  weeks to get a better overview of the system.
- HCC Phil and Steve are trying to compartmentalize their issues and have APE finish the install of the air-release valves and pressure gauges now, and then taking a longer-term view of the well/pump issue. For now, George is running the system manually and so the water is passing through the Isolux system. They are aware of the issues raised about the tank in the sanitary survey and are still stuck in this in-between phase of whether or not to invest in the system if HAMP is going to come. They would like to put together a budget for replacing the tank and the well/pump and presenting that to the Tribe.
- Bacavi Robbie is still out on medical leave but Marco seems to be doing fine, completing the BacT samples, etc.
- Upper Moenkopi Fred finished the install of the grit removal auger at the SBR.

Thanks, Brett

Brett Gleitsmann
RCAC | Environmental
Rural Development Specialist | Arizona
(928) 864-7597
www.rcac.org